FC5 - <offline>

""

Name: **Family:**
Author: **Version:** 0.1
Block version: 2
Time stamp Code: 14/05/2011 13:18:38
Interface: 24/03/2011 8:57:25
Lengths (block/logic/data): 00468 00326 00036

Name	Data Type	Address	Comment
IN		0.0	
OUT		0.0	
IN_OUT		0.0	
TEMP		0.0	
RET	Word	0.0	
afgerond	DInt	2.0	
DInaarBCD	DWord	6.0	
re_val	Int	10.0	
re_val_1	Int	12.0	
datum_tijd	Date_And_Time	14.0	
tijd	Time_Of_Day	22.0	
RETURN		0.0	
RET_VAL		0.0	

Block: FC5

Network: 1



Network: 2



Network: 3



Network: 4



Network: 5



Network: 6



Network: 7



Network: 8



Network: 9

```
      A     I    124.0
      R     Q    125.0

      AN    M     10.2
      BEC

      A     M     12.1
      OPN   DB     1

      O     M     13.1
      OPN   DB     2

      O     M     14.1
      OPN   DB     3

      L     0
      T     MD    80
      L     8
      T     MD    60

ln1:  L     DBB [MD 60]
      T     DBB [MD 80]  //wegschrijven van een meting naar de databouwsteen

      L     MD    60
      +     8            // verschuiven iedere keer 1 plaats naar onder pointer 1
      T     MD    60

      L     MD    80     // ponter 2 telkens 1 p^laats naar onder bij bereiken 10 plaats gegevens naar
      +     8
      T     MD    80     // telkens 1 plaats naar boven halen en laatste waarde bijschrijven op 10 plaats

      L     72

      <D
      JC    ln1

      L     MB   114
      T     DBB [MD 80]









// L     MD    80                    //eerste buffer
// +     8
//T     MD    80


// L     MD    80
// L     80
//<D
// BEC
//L     0
// T     MD    80

      AN    Q    125.0   //eerste-buffer-is-vol-indicator
      S     Q    125.0

//OPN   DB     1                    // pointer eerste volgende 1 naar boven van onder bij schrijven
//L     MD    80
//T     DBB [MD 60]                 //wegschrijven van een meting naar de

// L     MD    60                    //eerste buffer
//+     8
//T     MD    60
//<D
//BEC
//L     0
//T     MD    60
```